

INDUSTRIAL COMPANY ELECTRICAL



TECHNICAL SPECIFICATION

400Amp Ring Pillar

System :	380V ,3PHASE, 50 HZ
Product No :	6
Designation :	400Amp Ring pillar
Construction :	outdoor (H=895mm,W=1035mm,D=270mm)
Incomer ;	2x400A, 3P,MCCB,36KA
Bus Bar:	400A, TPN&E at 50C,
Bus bar :	320Amp TPN&E at 50 deg c
Outgoing :	6x200A,3P MCCB,25KA (Cable connection)
Cable Entries:	Bottom front
Finishing :	light grey RAL 7032

LD8A007AD M0

DO NOT SCALE
FROM 3 UNIT SET



EICO, LTD.

MATERIAL: MS SH1 2mm THK.
FINISH: PWD SPEC 204A

DESCRIPTION	QUANTITY	UNIT	REVISION
4000 RING PILLAR	1	EA	
DATE: 2004.08.10			
DESIGNED BY: [Signature]			
CHECKED BY: [Signature]			
DATE: 2004.08.10			
PROJECT NO: LD8A007AD M0			
SCALE: 1:1			
CONFORMS AND COMPLIES TO SPEC. IES.			
ALL DIMENSIONS IN MM.			